

# Energy performance certificate (EPC)

Unit 2a-2b Rear of 7 Gathurst Road ORRELL WN5 8QJ	Energy rating <h1 style="font-size: 2em; margin: 0;">D</h1>	Valid until: <b>15 February 2033</b> <hr/> Certificate number: <b>1961-3394-7450-0580-1824</b>
--	--	---

Property type General Industrial and Special Industrial Groups


Total floor area 664 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

## Energy efficiency rating for this property

This property's current energy rating is D.



Properties are also given a score. The larger the number, the more carbon dioxide (CO2) your property is likely to emit.

## How this property compares to others

Properties similar to this one could have ratings:

If newly built 20 | A

If typical of the existing stock 81 | D

Properties are given a rating from A+ (most efficient) to G (least efficient).

## Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Mechanical Ventilation
Assessment level	3
Building emission rate (kgCO <sub>2</sub> /m <sup>2</sup> per year)	22.01
Primary energy use (kWh/m <sup>2</sup> per year)	168

## Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/9862-0120-4921-6957-6439\)](#).

## Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

### Assessor contact details

Assessor's name	KENNETH FRITH
Telephone	01925212967
Email	<a href="mailto:info@clearenergyreports.co.uk">info@clearenergyreports.co.uk</a>

### Accreditation scheme contact details

Accreditation scheme	Stroma Certification Ltd
Assessor ID	STRO001414
Telephone	0330 124 9660
Email	<a href="mailto:certification@stroma.com">certification@stroma.com</a>

### Assessment details

Employer	CLEAR ENERGY REPORTS
Employer address	18 WARREN DRIVE, APPLETON, WARRINGTON, WA4 5BN
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	13 February 2023
Date of certificate	16 February 2023

---