Energy performance certificate (EPC)

Unit 4 Howarth Court Gateway Crescent Oldham Broadway Business Park OLDHAM OL9 9XB Energy rating

Valid until: 10 October 2027

Certificate number: 0070-0033-9369-9990-0096

Property type

B1 Offices and Workshop businesses

Total floor area


1,046 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

.

28 B

If typical of the existing stock

If newly built

81 D

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	58.77
Primary energy use (kWh/m2 per year)	348

Recommendation report

Guidance on improving the energy performance of this property can be found in the $\frac{\text{recommendation report}}{(\text{/energy-certificate/9900-7930-0463-9090-0090})}$.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name Guy Shorrock

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO002747
Telephone	0330 124 9660
Email	certification@stroma.com

About this assessment

Employer	Aldrock Surveyors Ltd
Employer address	5 Cunningham Court, Lions Drive, Blackburn BB1 2QX
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	10 October 2017
Date of certificate	11 October 2017